

**PRINCIPALS**

Daniel W. Mitchell  
Nancy M.D. Faught  
Jesse B. VanDeCreek  
Roland N. Alix  
Michael C. MacDonald  
James F. Burton  
Charles E. Hart  
Todd J. Sneathen

**CONTROLLER**

Donna M. Martin

**SENIOR ASSOCIATES**

Gary J. Tressel  
Randal L. Ford  
William R. Davis  
Dennis J. Benoit  
Robert F. DeFrain  
Thomas D. LaCross  
Albert P. Mickalich  
Timothy H. Sullivan  
Thomas G. Maxwell

**ASSOCIATES**

Marshall J. Grazioli  
Colleen L. Hill-Stramsak  
Bradley W. Shepler  
Karyn M. Stickel  
Jane M. Graham  
Aaron A. Uranga  
Salvatore Conigliaro  
Melissa A. Coatta  
Michael P. Darga  
Brian K. Davies  
Matthew G. Slicker  
James J. Surhigh  
Trevor S. Wagenmaker

**HUBBELL, ROTH & CLARK, INC.**

STREET: 105 W. Grand River  
Howell, MI 48843

PHONE: 517-552-9199

WEBSITE: hrcengr.com

**OTHER OFFICE LOCATIONS**

Bloomfield Hills  
Delhi Township  
Detroit  
Grand Rapids  
Jackson  
Kalamazoo  
Lansing

**ADDENDUM NO. 1  
2019 PARKING LOT PROGRAM (GIBSON HOUSE)  
CITY OF WIXOM  
OAKLAND COUNTY, MICHIGAN**

March 6, 2019

HRC Job No. 20180738

**ONLINE ONLY**

<http://www.hrcengr.com/bid-info/>

**INTENT:**

This Addendum No. 1 is issued prior to receipt of bids to provide for certain changes and clarifications to the specifications and/or the plans, as herein specified, and is hereby made a part of the Contract Documents and shall be taken into consideration in preparing the Proposal. The General Conditions and Specifications for the original work and the Contract Drawings are to govern this work unless otherwise revised herein. All other conditions remain the same.

**CONTRACTOR INQUIRY**

- Q1. The site preparation is a lump sum unit, but I do not see existing grades on the plans, are these available? We need them to calculate our cut and fills for this site.
- A1. The existing grades are not available. The proposed grades were designed to be as close to the existing grade as possible. Our analysis determined that the total cut is approximately 370 cubic yards and the total fill is approximately 86 cubic yards.
- Q2. There are details for guard rail, fence, storm sewer, water main, and sanitary sewer, but there is none on the plans. Were these inadvertently added?
- A2. These details are shown on the City of Wixom Standard detail sheets and not all details apply to the project.
- Q3. On the general standard sheet, it shows ADA tile on the concrete ramps, but they are not indicated on the plans or the bid quantities. Will they be required? If so how many?
- A3. ADA detectable warning surfaces are not a part of this project.

The Bidder shall acknowledge receipt of this Addendum No. 1 by signing in the location provided below and incorporating this Addendum No. 1 with the submission of his bid.

Failure to include Addendum No. 1 and its attachments may result in rejection of the bid.

Very truly yours,

HUBBELL, ROTH & CLARK, INC.



Paul Koppana, P.E.

PLK

Attachment

pc: All Prospective Bidders  
City of Wixom; Tim Sikma, Jodi Gallo  
HRC; N. Faught, M. Darga, K. Stickel, A. Malczewski, N. Womack, S. Carver,

File

Accepted by:

Company Name: \_\_\_\_\_

Name: \_\_\_\_\_

Written Name: \_\_\_\_\_

Address: \_\_\_\_\_

Telephone: \_\_\_\_\_ Fax: \_\_\_\_\_