

**ADDENDUM NO. 3  
TO SPECIFICATIONS FOR THE  
LONG LAKE PRV PROJECT  
BLOOMFIELD TOWNSHIP  
OAKLAND, MICHIGAN**

ISSUED: April 10, 2020

HRC Job No. 20190296

This Addendum is issued prior to receipt of proposals to provide for certain changes and clarifications to the Specifications and/or the Drawings, as herein specified, and is hereby made a part of the Contract Documents and shall be taken into consideration in preparing the Proposal. All other conditions remain the same. **The Proposer shall acknowledge the receipt of this Addendum by signing below, including this addendum with their proposals, and completing the Addenda section on Page 3 of the Proposal Form (Section 00300).** Failure to sign the Addenda Section of the Proposal Form in the submission of the proposal may be justification for the proposal being rejected as non-responsive.

**Mentioning again, due to the uncertainty of the current situation, the Township is allowing for the substantial and final completion dates to be negotiated upon contract award if necessary.**

The following lists the extent of this Addendum. Descriptions of the changes or clarifications are given within each heading.

**SPECIFICATIONS**

**ISSUED/REISSUED:**

00010 – Table of Contents – Reissued in its entirety  
00300 – Proposal – Reissued Pg 2  
01220 – Bid Item Description – Reissued Pgs 5-7  
02315 – Utility Trenching, Backfill and Compaction -Issued in its entirety  
02660 – Water Systems- Reissued in its entirety  
02661 –Ductile-Iron Water Main Pipe – Reissued in its entirety  
15410 – General Piping and Valves – Reissued in its entirety

**DRAWINGS**

**ISSUED/REISSUED:**

C-1 – Reissued  
P-1 - Reissued  
WM STANDARD DETAIL SHEET – Reissued

**CLARIFICATIONS**

**Question:**

With regard to the site pipe materials the specs seem to indicate only C110 MJ fittings are allowed along with 304SS T-bolts and nuts. However, there are comments on the Water Main Standard Details (last plan sheet) that indicate C153 would be acceptable along with Corten bolts and nuts for buried.

<b>Delhi Township</b> 2101 Aurelius Rd. Suite 2A Holt, MI 48842 517-694-7760	<b>Detroit</b> 535 Griswold St. Buhl Building, Ste 1650 Detroit, MI 48226 313-965-3330	<b>Grand Rapids</b> 1925 Breton Road SE Suite 100 Grand Rapids, MI 49506 616-454-4286	<b>Howell</b> 105 W. Grand River Howell, MI 48843 517-552-9199	<b>Jackson</b> 401 S. Mechanic St. Suite B Jackson, MI 49201 517-292-1295	<b>Kalamazoo</b> 834 King Highway Suite 107 Kalamazoo, MI 49001 269-665-2005	<b>Lansing</b> 215 S. Washington SQ Suite D Lansing, MI 48933 517-292-1488
--	--	---	---	---	--	--

**Clarification:**

C153 fittings are allowed, the specs that were added per Addendum #3 reflect their acceptability for use. Regarding specified hardware, the specifications added as part of Addendum #3 clarify the use of fluoropolymer epoxy coated "Blue Bolts" (refer to the specifications for further detail) for all buried applications (including within gate well structures) and 316 stainless steel for all hardware internal to the vault structure.

Received and Acknowledged By:

Company: \_\_\_\_\_

Signature: \_\_\_\_\_

Printed Name: \_\_\_\_\_

Title: \_\_\_\_\_

Date: \_\_\_\_\_