

**ADDENDUM NO. 2
TO SPECIFICATIONS FOR:
2021 SEWER REHABILITATION PROGRAM
BLOOMFIELD TOWNSHIP, MICHIGAN**

Issued: June 23, 2021

HRC Job No. 20210299

This Addendum is issued prior to receipt of proposals to provide for certain changes and clarifications to the Specifications and/or the Drawings, as herein specified, and is hereby made a part of the Contract Documents and shall be taken into consideration in preparing the Proposal. All other conditions remain the same. **The Proposer shall acknowledge the receipt of this Addendum by signing below, including this addendum with their proposals, and completing the Addenda section on Page 4 of the Proposal Form (Section 00300).** Failure to sign the Addenda Section of the Proposal Form in the submission of the proposal may be justification for the proposal being rejected as non-responsive.

The following lists the extent of this Addendum. Descriptions of the changes or clarifications are given within each heading:

SPECIFICATION CHANGES:

≡ None

PROSPECTIVE BIDDER QUESTIONS:

≡ Q: "Are there any videos that I can review of the lines?"

A: Refer to Section 02708 Part 1.2 (A): The Contractor is responsible for obtaining Pre-Installation TV Inspection videos for all sewers designated to receive a CIPP liner.

See also: Section 02708 Part 3.1 (H): It is the contractor's responsibility to determine if the condition of the host pipe is acceptable to receive the CIPP Installation.

The Township DPS is not releasing videos used during the design phase of this study due to the high amount of electronic memory and distribution needs, and therefore, no, there are not any videos to review at this time.

≡ Q: "For the CIPP Spot Lining, the areas in question are less than 4' foot length. Is it possible to get a more accurate spot lining price, to make the three proposed spot liners an each price with a 4' maximum?"

A: The three (3) sectional CIPP Spot Liners during the design review were assumed to be a maximum of 10 linear feet at each specified repair location on Page 3 of the plans, based on the defect observed in the pre-study CCTV video.

≡ Q: "The heavy cleaning line item for Division 3- If used, will the contractor be paid the normal cleaning price and then the heavy cleaning price in addition to or it is one or the other. That affects pricing"

Delhi Township 2101 Aurelius Rd. Suite 2A Holt, MI 48842 517-694-7760	Detroit 535 Griswold St. Buhl Building, Ste 1650 Detroit, MI 48226 313-965-3330	Grand Rapids 1925 Breton Road SE Suite 100 Grand Rapids, MI 49506 616-454-4286	Howell 105 W. Grand River Howell, MI 48843 517-552-9199	Jackson 401 S. Mechanic St. Suite B Jackson, MI 49201 517-292-1295	Kalamazoo 834 King Highway Suite 107 Kalamazoo, MI 49001 269-665-2005	Lansing 215 S. Washington SQ Suite D Lansing, MI 48933 517-292-1488
---	---	--	--	--	---	---

A: Refer to Section 01001, Part 2 (d): Should the sewer line have too much debris or blockage to allow a camera to pass through after the original three passes are made, additional cleaning may be required. This work shall commence only upon the approval and direction of the Owner and/or the Owner's Representative/Engineer and the Contractor will be paid to remove any blockages under the pay item. Contractor shall be responsible for making any provisions for the successful completion of the specified televising. Where sags or submerged sections of the sewer are encountered during TV inspection, the contractor shall first complete inspection of the entire reach to determine the extent of such areas prior to dewatering the sewer. Dewatered sections of the sewer shall then be TV inspected.

Heavy Cleaning is authorized via Change Order, and it is the responsibility of the Contractor to inform the Owner and/or Engineer that the sewer line could not be inspected after the original three passes are attempted. The contractor should be prepared to submit first attempt video or documentation of the sewer line obstruction/conditions.

SUMMARY:

This Addendum No. 2 has been issued in order to clarify, modify, and add additional items to the original Bid Package. A copy of the amended pages of the Contract Documents noted in this addendum have been posted online at <http://www.hrcengr.com/bid-info>. The Bidder shall acknowledge receipt of this Addendum No. 1 by signing in the location provided below and incorporating this Addendum No. 1 with the submission of his bid. Failure to include Addendum No. 1 and its attachments may result in rejection of the bid.

If you have any questions or require any additional information, please contact the undersigned.

Respectfully submitted,

HUBBELL, ROTH & CLARK, INC.



Matthew G. Hughes, P.E.
Staff Engineer

Attachment

Enclosure

pc: All Plan holders
Bloomfield Township; O. Olstzyn-Budry, C. Borton
HRC; K. Stickel, S. Carver (Front Desk), N. Womack (Repro) File

Received and Acknowledged By:

Company: _____

Signature: _____

Printed Name: _____

Title: _____

Dated: _____