

**ADDENDUM NO. 1  
TO SPECIFICATIONS  
FOR THE  
2021 CONCRETE PATCH REPAIR PROGRAM  
VILLAGE OF BEVERLY HILLS  
OAKLAND, MICHIGAN**

ISSUED: July 30, 2021

HRC Job No. 20210379

This Addendum is issued prior to receipt of proposals to provide for certain changes and clarifications to the Specifications and/or the Drawings, as herein specified, and is hereby made a part of the Contract Documents and shall be taken into consideration in preparing the Proposal. All other conditions remain the same. **The Proposer shall acknowledge the receipt of this Addendum by signing below, including this addendum with their proposals, and completing the Addenda section on Page 3 of the Proposal Form (Section 00300).** Failure to sign the Addenda Section of the Proposal Form in the submission of the proposal may be justification for the proposal being rejected as non-responsive.

The following lists the extent of this Addendum. Descriptions of the changes or clarifications are given within each heading.

**CONTRACTOR QUESTIONS**

Q: What is the Engineer's Estimate?  
A: \$500,000.00

Q: Will Contraction, Crg and Expansion, Erg joints be required as detailed in the Michigan Department of Transportation Concrete Pavement Repair detail?  
A: No, Contraction, Crg and Expansion, Erg joints will not be required. However, if an expansion joint in encountered during construction, Expansion Joint, Esc will be used. Costs for Expansion Joint, Esc shall be included in the contractor's bid unit price for "Pavt Repr, Nonreinf Conc, 7 inch, Special – Syd"

Q: Will Load Transfer Assemblies (baskets) be required?  
A: No, Load Transfer Assemblies (baskets) are not required.

Received and Acknowledged By:

Company: \_\_\_\_\_

Signature: \_\_\_\_\_

Printed Name: \_\_\_\_\_

Title: \_\_\_\_\_

Date: \_\_\_\_\_