



**ADDENDUM NO. 2
TO SPECIFICATIONS AND PLANS FOR THE
2025 SAFETY PATH PROGRAM (W. MAPLE ROAD)
BLOOMFIELD TOWNSHIP
OAKLAND COUNTY, MICHIGAN**

Date: April 14, 2025,

HRC Job No. 20240038

This Addendum is issued prior to receipt of bids to provide for certain changes or clarifications to the Specifications and/or the Plans, as herein specified, and is hereby made a part of the Contract Documents and shall be taken into consideration in preparing the Proposal. The General Conditions and Specifications for the original work and the Contract Drawings are to govern this work unless otherwise revised herein. All other conditions remain the same.

The Bidder shall acknowledge the receipt of this Addendum by signing this Addendum and enclosing it in the submission of his bids. This must also be acknowledged on Page 4 of the Proposal. The proposal included in this Addendum must be submitted for the bid to be considered responsive. Failure to enclose Addendum No. 2 in the submission of bids may be justification for the bid proposal being rejected as non-responsive.

The following lists the extent of this Addendum. Description of the changes or clarifications are given within each heading:

CLARIFICATION:

1. Construction of base material for Safety Path construction shall all be aggregate material conforming to Michigan Department of Transportation (MDOT) 21AA aggregate, and crushed concrete may be used except within 100 feet of any water course (stream, river, county drain, etc.) or lake, regardless of the application or location of the water course or lake relative to the project limits.

SUMMARY:

This Addendum No. 2 has been issued to clarify the use of crushed concrete for Safety Path base material. A copy of the amended pages of the Contract Documents noted in this Addendum No. 2 have been posted online at <http://www.hrcengr.com/bid-info>, www.bidnetdirect.com/mitn and should be utilized during the preparation of bids and incorporated into the Bid Documents.

The Bidder shall acknowledge receipt of this Addendum No. 2 by signing in the location provided below and incorporating this Addendum No. 2 with the submission of his bid. Failure to include Addendum No. 2 and its attachments may result in rejection of the bid.

Respectfully submitted,

HUBBELL, ROTH & CLARK, INC.



Karyn M. Stickel, P.E.
Senior Associate



Melissa Fickel
Project Engineer

pc: All plan holders

Bloomfield Township; R.C. Almas, A. Kozlowski
HRC; File

Received and Acknowledged By:

Company: _____

Signature: _____

Printed Name: _____

Title: _____

Date: _____